



***PREMIUM* Certificate**

Customer: ADC KRONE
Beeskowdamm 3-11
D-14167 Berlin, Germany

Description: **TrueNet[®] KM8 RJ45 Patch cord,
shielded S-FTP LSZH**

Part-No.: **6830 2 86x-yy** (x=colour, yy=length)

Applied standards: ISO/IEC 11801: 2002-09
Information technology – Generic cabling for customer premises
EN 50173-1: 2007-12
Information technology – Generic cabling systems Part 1
ANSI/TIA-568-B.2-1 (Addendum No.1 to TIA/EIA-568-B.2) - June 2002
Transmission Performance Specifications for 4-Pair 100Ω Category 6 Cabling
IEC 61935-2: 2005
Generic cabling systems – Specification for the testing of balanced communication cabling in accordance with EN 50173 – Part 2: Patch cords and work area cords

Comments: Up to a bandwidth of **250 MHz**, the sample, a **Category 6 Patch cord**, meets the limits of the specified standards and regulations.

This certificate, based on participation in the **GHMT PREMIUM Verification Program**, authorizes to apply the GHMT PREMIUM marking. Ongoing compliance with the specifications is monitored within the framework of regular sampling, which cannot be influenced by the customer, thus defining high standards as regards continuous manufacturing quality.

This Certificate refers to the comprehensive test report, **no. P1306j-04-E, from February 06th 2009** and shall only be applicable in conjunction with the test report.

Bexbach, February 06th 2009

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
E-Mail: info@ghmt.de
<http://www.ghmt.de>

valid until: July 31st 2009

